



ECOLINE EMERGENCY SL9732TC/DP3EM - 10/40W

MAINTAINED OR NON-MAINTAINED - Compliant to AS/NZS 2293, narrow body profile

Application

Perfect for interior commercial emergency lighting installations

Design Specifications

- Narrow steel body (65mm) body profile, white powder coat finish
- LiFePO4 battery technology for long life
- Designed for both maintained and non-maintained systems
- Selectable CCT 3000K / 4000K / 5700K
- Selectable maintained power
- LED charge status display and test switch, guaranteed 90 minutes emergency function Note: 20EM = D50C0, D32@C90, 40EM = D50@C0, D32@C90 emergency classification



Technical Specification


Product	Model No.	Input Voltage (V/AC)	CCT (K)	CRI	Dim (mm)
	SL9732/40TC/DP3EM	240	3000/4000/5700	80	1135(L) x 65(W) x 65(H)

Important notes: (1) Battery warranty twelve (12) months (2) In the interest of transport and safety, emergency products are supplied with the battery disconnected. (3) In addition to specific emergency commissioning instructions, the battery MUST be connected at the time of installation. (4) Continual use in emergency mode greater than 240 hours without recharge, will result in battery failure and void battery warranty.


Due to continued product and technology enhancements, data sourced from sal.net.au shall not form part of any contract and or technical performance guarantee unless expressly confirmed in writing by SAL at the time of order. Products are sold in accordance with [SAL Terms and Conditions of sale](#) and all images shown are for illustration purposes only and may vary from the actual colour or finish. Unless specifically stated, all IP ratings nominated for Interior products are from "below the ceiling".

Dimensions

SL9732 40



SL9732 20





Blackwattle Bay NSW

Images courtesy of MKGS Construction & Paton Power

The difference between Non-maintained and Maintained Emergency Lighting? Non-Maintained lighting products are luminaires designed solely for emergency use and will only operate in an event where the mains supply power is interrupted. Maintained Emergency Lighting products are designed to be illuminated at all times, including an emergency event where the power is interrupted. Under both systems, the products must remain illuminated for a period of 90 minutes in accordance with AS/NZS2293 Emergency Lighting requirements.

